WE SERVE TO SAVE

DEPARTMENT OF FIRE AND RESCUE SERVICES
GOVERNMENT OF KERALA

No: FRS/KHD/15090/2026/RENEWAL Date:11-8-2026

RENEWAL CERTIFICATE

NAME & ADDRESS OF THE APPLICANT	:	PRINCIPAL, CHINMAYA VIDYALAYA,ATHIYAMBUR,KANHANGAD,KASARAGOD-671315
NAME OF THE COMPANY	:	
OCCUPANCY TYPE	:	EDUCATIONAL BUILDING
HEIGHT OF THE BUILDING	:	11.75 Metre
NO OF FLOOR	:	G+2 (3 FLOORS)
BUILT UP AREA	:	4429.06 m²
FINAL NOC NO. AND DATE OF ISSUE AND ISSUED BY	:	FRS/14/KHD/17183/2023/FINAL dated 29-07-2023 Issued by REGIONAL FIRE OFFICER KANNUR
SURVEY NO	:	185&186
VILLAGE	:	AJANUR
PANCHAYAT	:	AJANUR
DISTRICT	:	KASARAGOD

1.The Board headed by the Station Officer,Fire and Rescue station,KANJANGAD has inspected the above said building and recommended to renew the No objection Certificate.

2. In this circumstances, this No Objection Certificate is issued under my authority for the continued occupation of the above building. No further construction will be allowed in the vacant spaces provided in the approved plan.

3. This certificate is issued on the condition that the fire fighting system installed will be kept always functional and the owner of the building should take special care to maintain the systems installed in proper working condition in all time. **This certificate is valid for 5 years from the date of issue. After 5 years the certificate must be renewed. Non renewal of the certificate within the time limit will result in the loss of eligibility for insurance coverage and appropriate legal action by the Local Self Government/Revenue Department,** All Officers of and above the rank of Station Officers of the Fire & Rescue Services Department will have the right to inspect the building on any day/time after serving 7 days notice to ensure that the installed systems are in good working condition.

Certificate issued by Adarsh Asokan
Station Officer : KANJANGAD
Date of Issue 11-08-2026 16:52:19
Next Renewal Date:11-08-2031

To,
Applicant / Concerned Local Authority

** This is a Computer Generated Certificate & signature is not required.*